

June 2021

DOC/21/25432

Inspection and Maintenance Checklist Solar Energy Systems

Solar energy systems should be regularly inspected and maintained to ensure that they continue to function safely and efficiently.

This checklist provides guidance on what should be checked and why. It applies to photovoltaic (PV) solar energy systems, not solar hot water systems.

Who can do the maintenance?

Maintenance of electrical installations in Tasmania, including solar energy systems, must be performed by a licensed electrician. Search the database "Find a Licensed Tradesperson" on the CBOS website www.cbos.tas.gov.au

How often should the inspections be done?

Electricians can provide advice on recommended inspection frequency. This will depend on various factors including site conditions. As a guide, solar energy systems should be inspected annually.

Can I alter the checklist?

This checklist is provided as an example only. Other maintenance information may have been provided when the system was first installed. Electricians may also customise this form to suit their needs or those of a specific installation (such as large, complex solar energy systems).

Please note that there is no requirement for existing electrical installations to be upgraded to meet more recent requirements contained within later Standards.

Record keeping

Inspection and maintenance checklists should be completed by the electrician performing the inspection, and a copy given to the owner for their records. Owners should keep records of all inspections and maintenance of their solar energy systems along with the documents provided when the system was originally installed. These records may be useful in the event of a warranty or insurance claim, or if the property is being sold.

This document has been produced and published by the Consumer, Building and Occupational Services Division of the Department of Justice. Although every care has been taken in the production of the work, no responsibility is accepted for the accuracy, completeness, or relevance to the user's purpose, of the information. Those using it for whatever purpose are advised to verify it with the relevant government department, local government body or other source and to obtain any appropriate professional advice. The Crown, its officers, employees and agents do not accept liability however arising, including liability for negligence, for any loss resulting from the use of or reliance upon the information and/or reliance on its availability at any time.



Inspection and Maintenance Checklist Solar Energy Systems

Property details:

Address	Suburb	Owner name

Advanced Meter	Yes	No	Meter No

Solar energy system details:

Inverter brand(s)	Inverter rating	Input A		Input B		Output current
	W	٧	А	٧	А	Α
	W	٧	А	٧	А	А
	W	٧	А	٧	А	А

Micro-inverters	Yes	No	Power optimisers	Yes	No
-----------------	-----	----	------------------	-----	----

Inspection and maintenance checklist:

System component	Inspect to ensure	✓ or X	Reason for check	Inspector notes (E.g. actions taken)
Site	Array is not shaded		Encroaching vegetation may shade the array	
	All debris from around or under the array is removed		The build-up of debris may result in roof corrosion from the backing up of water	
PV modules and arrays including mounting structures	All individual modules are clean		Dirt, grime, algae growth and bird droppings on the module may affect performance	

System	Inspect to	✓ or X		Inspector notes
component	ensure		check	(E.g. actions taken)
	No visual defects in modules		Cracks or glass damage will result in moisture ingress	
PV modules and arrays including mounting structures	No browning or discolouration		Panel discolouration may indicate an internal panel fault	
	No indication of moisture penetration		Internal moisture ingress will result in panel failure	
	No indication of corrosion on the frame or mountings		Ferrous metals may corrode, and salt laden atmospheres can increase the risk of corrosion	
	Array still firmly fixed to roof structure		Loose or missing fixings may result in wind damage	
	Individual modules still firmly fixed to array structure No loose or missing panel clamps		Loose or missing panel clamps may result in modules dislodging during wind	
	Roof penetrations adequately sealed		Inadequate sealing will lead to moisture ingress	
Wiring systems and enclosures	Conduits and cables are adequately supported		Cables and conduit in contact with the roof surface may cause abrasion	

System	Inspect to	✓ or X	Reason for	Inspector notes
component	ensure		check	(E.g. actions taken)
Wiring systems and	Conduits and cables are free of deterioration from UV or mechanical damage		Damage or deterioration to cables and conduit may cause moisture ingress or short circuits	
enclosures	Cables not damaged by stainless steel cable ties		Damage to cables may cause moisture ingress or short circuits	
	Connectors show no signs of deterioration (deterioration may be caused by poor or mismatched connectors)		Deteriorated connectors may cause overheating resulting in failure	
	Connections are not frayed, loose or corroded		Poor connections may cause overheating resulting in failure	
	Conduit ends are adequately sealed		Moisture ingress into conduits may result in cable deterioration or moisture within enclosures	
	Enclosures are adequately sealed and show no signs of moisture ingress		Moisture ingress into an enclosure may result in an unsafe failure	

System component	Inspect to ensure	✓ or X	Reason for check	Inspector notes (E.g. actions taken)
	Enclosures showing no signs of internal heating		Enclosures that are warped or discoloured may be overheating internally which could create a fire risk	
Electrical characteristic	Verify open circuit voltage and short circuit currents	v	Values will indicate the array is still functioning correctly	
Protective devices and isolators	Fuses and holders are still intact		Essential for the correct performance of the system	
	Circuit breakers and residual current devices (RCD) operate correctly		Essential for the required electrical protection	
	Earth fault protection system operates correctly (if required refer to applicable requirements)		Essential for the safe operation of the system	
	Isolators function correctly, are able to be operated and are effective		Essential for the safe operation of the system	
	Isolators and other electrical equipment is not on the recalled list		Products with known safety issues may have been recalled	

System	Inspect to	✓ or X	Reason for	Inspector notes
component	ensure		check	(E.g. actions taken)
Labels and signage	Green PV label in place		This indicates to the fire service the presence of a solar energy system	
	Shut down procedure is still visible and legible		Instructs owner on how to safely shut down the system	
	Disconnecting devices are adequately labelled		Indicates the devices that are required to safely shut down the system	

Responsible electrician details:

I have completed an inspection and maintenance of the above solar energy system and confirm that the details provided in this document are true and correct.

Full name	Electrical practitioner's licence number	Electrical contractor's licence number	Signature	Date
Recommended date of	next inspection:		•••••	
General comments and	I notes of inspecting	g electrician (inclu	ding any items repla	ced):